

5 July 2024

OIA-700

7(2)(a)

Tēnā koe <mark>7(2)</mark>

Request for information – Fluoride levels in water

Thank you for your request received on 7 June 2024 for the following information:

Please supply all the fluoride measures of all water supplies that you manage for the year 2023. Please provide the data in a spreadsheet.

Your request is responded to in accordance with the Local Government Official Information and Meetings Act (LGOIMA – the Act) 1987. Please refer to the attached .csv spreadsheet titled *Fluoride_Lab_sampling_data*. This lab sampling data for Fluoride encompasses water leaving the treatment plant, certain reservoirs, and pump stations.

Please note that it is our policy to publicly release our responses to official information requests where possible. Our response to your request will be published shortly at https://www.wellingtonwater.co.nz/about-us/official-requests/official-information-act-responses/ with your personal information removed.

You have the right to seek an investigation and review by the Ombudsman of this decision. Information about how to make a complaint is available at <u>www.ombudsman.parliament.nz</u> or freephone 0800 802 602.

If you wish to discuss this decision with us, please feel free to email us at <u>official.information@wellingtonwater.co.nz</u>

7(2)(a) Group Manager

Network Management

Nāku noa, nā

For the latest news and updates, follow us on our social channels:

f /wellingtonwater

www.wellingtonwater.co.nz

@wellington_water

Our water, our future.

Wellington Water is owned by the Hutt, Porirua, Upper Hutt and Wellington City Councils, South Wairarapa District Council and Greater Wellington Regional Council. We manage their drinking water, wastewater and stormwater services.

() @wgtnwaternz & @wgtnwateroutage

Sampling Site Te-Marua Treated Water @ Pumping Station Te Marua Treated Water @ Pumping Station

4/01/2023 8:16 Fluoride0.65 mg/l11/01/2023 12:47 Fluoride0.6 mg/l17/01/2023 10:08 Fluoride0.71 mg/l25/01/2023 12:19 Fluoride0.69 mg/l31/01/2023 12:26 Fluoride0.7 mg/l8/02/2023 11:34 Fluoride0.76 mg/l14/02/2023 12:20 Fluoride0.7 mg/l22/02/2023 10:13 Fluoride0.77 mg/l28/02/2023 10:39 Fluoride0.79 mg/l8/03/2023 10:44 Fluoride0.76 mg/l14/03/2023 9:38 Fluoride0.69 mg/l22/03/2023 13:37 Fluoride0.77 mg/l28/03/2023 13:43 Fluoride0.78 mg/l11/04/2023 9:54 Fluoride0.78 mg/l11/04/2023 9:54 Fluoride0.77 mg/l3/05/2023 10:21 Fluoride0.76 mg/l17/05/2023 10:22 Fluoride0.76 mg/l3/05/2023 10:21 Fluoride0.76 mg/l3/05/2023 10:22 Fluoride0.76 mg/l3/05/2023 10:21 Fluoride0.76 mg/l3/05/2023 10:22 Fluoride0.77 mg/l3/05/2023 10:21 Fluoride0.77 mg/l3/05/2023 10:21 Fluoride0.76 mg/l17/05/2023 10:22 Fluoride0.77 mg/l3/05/2023 10:21 Fluoride0.76 mg/l3/05/2023 10:22 Fluoride0.77 mg/l3/05/2023 10:27 Fluoride0.76 mg/l3/05/2023 12:01 Fluoride0.76 mg/l3/05/2023 12:01 Fluoride0.76 mg/l	Sampling Date/Time	Parameter	Value	Unit
17/01/2023 10:08 Fluoride0.71 mg/l25/01/2023 12:19 Fluoride0.69 mg/l31/01/2023 12:26 Fluoride0.7 mg/l8/02/2023 11:34 Fluoride0.76 mg/l14/02/2023 12:20 Fluoride0.7 mg/l22/02/2023 10:13 Fluoride0.77 mg/l28/02/2023 10:39 Fluoride0.79 mg/l8/03/2023 10:44 Fluoride0.76 mg/l14/03/2023 9:38 Fluoride0.69 mg/l22/03/2023 13:37 Fluoride0.77 mg/l28/03/2023 13:43 Fluoride0.78 mg/l28/03/2023 13:43 Fluoride0.78 mg/l11/04/2023 9:54 Fluoride0.78 mg/l19/04/2023 8:52 Fluoride0.76 mg/l3/05/2023 10:21 Fluoride0.76 mg/l17/05/2023 10:22 Fluoride0.76 mg/l3/05/2023 10:21 Fluoride0.76 mg/l3/05/2023 10:21 Fluoride0.76 mg/l3/05/2023 10:21 Fluoride0.77 mg/l3/05/2023 10:21 Fluoride0.76 mg/l17/05/2023 10:22 Fluoride0.77 mg/l3/05/2023 10:21 Fluoride0.77 mg/l3/05/2023 10:21 Fluoride0.76 mg/l17/05/2023 10:21 Fluoride0.76 mg/l3/05/2023 10:21 Fluoride0.76 mg/l3/05/2023 10:27 Fluoride0.76 mg/l3/05/2023 10:27 Fluoride0.76 mg/l			0.65	mg/l
25/01/2023 12:19 Fluoride0.69 mg/l31/01/2023 12:26 Fluoride0.7 mg/l8/02/2023 11:34 Fluoride0.76 mg/l14/02/2023 12:20 Fluoride0.7 mg/l22/02/2023 10:13 Fluoride0.77 mg/l28/02/2023 10:39 Fluoride0.79 mg/l8/03/2023 10:44 Fluoride0.76 mg/l14/03/2023 9:38 Fluoride0.69 mg/l22/03/2023 13:37 Fluoride0.77 mg/l28/03/2023 13:43 Fluoride0.78 mg/l28/03/2023 13:43 Fluoride0.78 mg/l11/04/2023 9:54 Fluoride0.78 mg/l11/04/2023 9:54 Fluoride0.77 mg/l3/05/2023 10:21 Fluoride0.76 mg/l9/05/2023 10:21 Fluoride0.76 mg/l17/05/2023 10:22 Fluoride0.76 mg/l13/05/2023 10:27 Fluoride0.77 mg/l31/05/2023 12:01 Fluoride0.76 mg/l	11/01/2023 12:47	Fluoride	0.6	mg/l
31/01/2023 12:26 Fluoride0.7 mg/l8/02/2023 11:34 Fluoride0.76 mg/l14/02/2023 12:20 Fluoride0.7 mg/l22/02/2023 10:13 Fluoride0.77 mg/l28/02/2023 10:39 Fluoride0.79 mg/l8/03/2023 10:44 Fluoride0.76 mg/l14/03/2023 9:38 Fluoride0.69 mg/l22/03/2023 13:37 Fluoride0.77 mg/l28/03/2023 13:43 Fluoride0.78 mg/l28/03/2023 13:43 Fluoride0.78 mg/l11/04/2023 9:54 Fluoride0.78 mg/l19/04/2023 8:52 Fluoride0.77 mg/l3/05/2023 10:21 Fluoride0.76 mg/l17/05/2023 10:22 Fluoride0.76 mg/l13/05/2023 10:27 Fluoride0.77 mg/l31/05/2023 12:01 Fluoride0.76 mg/l	17/01/2023 10:08	Fluoride	0.71	mg/l
31/01/2023 12:26 Fluoride0.7 mg/l8/02/2023 11:34 Fluoride0.76 mg/l14/02/2023 12:20 Fluoride0.7 mg/l22/02/2023 10:13 Fluoride0.77 mg/l28/02/2023 10:39 Fluoride0.79 mg/l8/03/2023 10:44 Fluoride0.76 mg/l14/03/2023 9:38 Fluoride0.69 mg/l22/03/2023 13:37 Fluoride0.77 mg/l28/03/2023 13:43 Fluoride0.78 mg/l28/03/2023 13:43 Fluoride0.78 mg/l11/04/2023 9:54 Fluoride0.78 mg/l11/04/2023 9:54 Fluoride0.77 mg/l3/05/2023 10:21 Fluoride0.76 mg/l9/05/2023 10:22 Fluoride0.76 mg/l17/05/2023 10:22 Fluoride0.77 mg/l31/05/2023 10:27 Fluoride0.77 mg/l31/05/2023 12:01 Fluoride0.76 mg/l				-
14/02/2023 12:20 Fluoride0.7 mg/l22/02/2023 10:13 Fluoride0.77 mg/l28/02/2023 10:39 Fluoride0.79 mg/l8/03/2023 10:44 Fluoride0.76 mg/l14/03/2023 9:38 Fluoride0.69 mg/l22/03/2023 13:37 Fluoride0.77 mg/l28/03/2023 13:43 Fluoride0.78 mg/l28/03/2023 13:43 Fluoride0.78 mg/l11/04/2023 9:54 Fluoride0.78 mg/l11/04/2023 9:54 Fluoride0.77 mg/l3/05/2023 10:21 Fluoride0.76 mg/l9/05/2023 10:21 Fluoride0.76 mg/l17/05/2023 10:27 Fluoride0.77 mg/l31/05/2023 12:01 Fluoride0.76 mg/l	31/01/2023 12:26	Fluoride		-
14/02/2023 12:20 Fluoride0.7 mg/l22/02/2023 10:13 Fluoride0.77 mg/l28/02/2023 10:39 Fluoride0.79 mg/l8/03/2023 10:44 Fluoride0.76 mg/l14/03/2023 9:38 Fluoride0.69 mg/l22/03/2023 13:37 Fluoride0.77 mg/l28/03/2023 13:43 Fluoride0.78 mg/l28/03/2023 13:43 Fluoride0.78 mg/l11/04/2023 9:54 Fluoride0.78 mg/l11/04/2023 9:54 Fluoride0.77 mg/l3/05/2023 10:21 Fluoride0.76 mg/l9/05/2023 10:21 Fluoride0.76 mg/l17/05/2023 10:27 Fluoride0.77 mg/l31/05/2023 12:01 Fluoride0.76 mg/l	8/02/2023 11:34	Fluoride	0.76	mg/l
28/02/2023 10:39 Fluoride 0.79 mg/l 8/03/2023 10:44 Fluoride 0.76 mg/l 14/03/2023 9:38 Fluoride 0.69 mg/l 22/03/2023 13:37 Fluoride 0.77 mg/l 28/03/2023 13:43 Fluoride 0.78 mg/l 28/03/2023 13:43 Fluoride 0.78 mg/l 5/04/2023 11:43 Fluoride 0.78 mg/l 11/04/2023 9:54 Fluoride 0.78 mg/l 19/04/2023 8:52 Fluoride 0.77 mg/l 3/05/2023 10:21 Fluoride 0.76 mg/l 9/05/2023 14:51 Fluoride 0.76 mg/l 17/05/2023 10:27 Fluoride 0.77 mg/l 31/05/2023 12:01 Fluoride 0.77 mg/l	14/02/2023 12:20	Fluoride	0.7	mg/l
8/03/2023 10:44 Fluoride0.76 mg/l14/03/2023 9:38 Fluoride0.69 mg/l22/03/2023 13:37 Fluoride0.77 mg/l28/03/2023 13:43 Fluoride0.78 mg/l5/04/2023 11:43 Fluoride0.75 mg/l11/04/2023 9:54 Fluoride0.78 mg/l19/04/2023 8:52 Fluoride0.77 mg/l3/05/2023 10:21 Fluoride0.76 mg/l9/05/2023 10:22 Fluoride0.76 mg/l17/05/2023 10:12 Fluoride0.84 mg/l23/05/2023 12:01 Fluoride0.76 mg/l31/05/2023 12:01 Fluoride0.76 mg/l	22/02/2023 10:13	Fluoride	0.77	mg/l
14/03/2023 9:38 Fluoride0.69 mg/l22/03/2023 13:37 Fluoride0.77 mg/l28/03/2023 13:43 Fluoride0.78 mg/l5/04/2023 11:43 Fluoride0.75 mg/l11/04/2023 9:54 Fluoride0.78 mg/l19/04/2023 8:52 Fluoride0.77 mg/l3/05/2023 10:21 Fluoride0.76 mg/l9/05/2023 14:51 Fluoride0.76 mg/l17/05/2023 10:27 Fluoride0.84 mg/l23/05/2023 12:01 Fluoride0.76 mg/l31/05/2023 12:01 Fluoride0.76 mg/l	28/02/2023 10:39	Fluoride	0.79	mg/l
22/03/2023 13:37 Fluoride0.77 mg/l28/03/2023 13:43 Fluoride0.78 mg/l5/04/2023 11:43 Fluoride0.75 mg/l11/04/2023 9:54 Fluoride0.78 mg/l19/04/2023 8:52 Fluoride0.77 mg/l3/05/2023 10:21 Fluoride0.76 mg/l9/05/2023 14:51 Fluoride0.76 mg/l17/05/2023 10:27 Fluoride0.84 mg/l23/05/2023 12:01 Fluoride0.76 mg/l	8/03/2023 10:44	Fluoride	0.76	mg/l
28/03/2023 13:43 Fluoride 0.78 mg/l 5/04/2023 11:43 Fluoride 0.75 mg/l 11/04/2023 9:54 Fluoride 0.78 mg/l 19/04/2023 8:52 Fluoride 0.77 mg/l 3/05/2023 10:21 Fluoride 0.76 mg/l 9/05/2023 14:51 Fluoride 0.76 mg/l 17/05/2023 10:12 Fluoride 0.84 mg/l 23/05/2023 10:27 Fluoride 0.77 mg/l 31/05/2023 12:01 Fluoride 0.76 mg/l	14/03/2023 9:38	Fluoride	0.69	mg/l
5/04/2023 11:43 Fluoride0.75 mg/l11/04/2023 9:54 Fluoride0.78 mg/l19/04/2023 8:52 Fluoride0.77 mg/l3/05/2023 10:21 Fluoride0.76 mg/l9/05/2023 14:51 Fluoride0.76 mg/l17/05/2023 10:12 Fluoride0.84 mg/l23/05/2023 10:27 Fluoride0.77 mg/l31/05/2023 12:01 Fluoride0.76 mg/l	22/03/2023 13:37	Fluoride	0.77	mg/l
11/04/2023 9:54 Fluoride0.78 mg/l19/04/2023 8:52 Fluoride0.77 mg/l3/05/2023 10:21 Fluoride0.76 mg/l9/05/2023 14:51 Fluoride0.76 mg/l17/05/2023 10:12 Fluoride0.84 mg/l23/05/2023 10:27 Fluoride0.77 mg/l31/05/2023 12:01 Fluoride0.76 mg/l	28/03/2023 13:43	Fluoride	0.78	mg/l
19/04/2023 8:52 Fluoride0.77 mg/l3/05/2023 10:21 Fluoride0.76 mg/l9/05/2023 14:51 Fluoride0.76 mg/l17/05/2023 10:12 Fluoride0.84 mg/l23/05/2023 10:27 Fluoride0.77 mg/l31/05/2023 12:01 Fluoride0.76 mg/l	5/04/2023 11:43	Fluoride	0.75	mg/l
3/05/2023 10:21 Fluoride0.76 mg/l9/05/2023 14:51 Fluoride0.76 mg/l17/05/2023 10:12 Fluoride0.84 mg/l23/05/2023 10:27 Fluoride0.77 mg/l31/05/2023 12:01 Fluoride0.76 mg/l	11/04/2023 9:54	Fluoride	0.78	mg/l
9/05/2023 14:51 Fluoride0.76 mg/l17/05/2023 10:12 Fluoride0.84 mg/l23/05/2023 10:27 Fluoride0.77 mg/l31/05/2023 12:01 Fluoride0.76 mg/l	19/04/2023 8:52	Fluoride	0.77	mg/l
17/05/2023 10:12 Fluoride0.84 mg/l23/05/2023 10:27 Fluoride0.77 mg/l31/05/2023 12:01 Fluoride0.76 mg/l	3/05/2023 10:21	Fluoride	0.76	mg/l
23/05/2023 10:27 Fluoride0.77 mg/l31/05/2023 12:01 Fluoride0.76 mg/l	9/05/2023 14:51	Fluoride	0.76	mg/l
31/05/2023 12:01 Fluoride 0.76 mg/l	17/05/2023 10:12	Fluoride	0.84	mg/l
	23/05/2023 10:27	Fluoride	0.77	mg/l
	31/05/2023 12:01	Fluoride	0.76	mg/l
6/06/2023 12:49 Fluoride 0.85 mg/l	6/06/2023 12:49	Fluoride	0.85	mg/l
14/06/2023 11:15 Fluoride 0.82 mg/l	14/06/2023 11:15	Fluoride	0.82	mg/l
20/06/2023 12:14 Fluoride 0.85 mg/l	20/06/2023 12:14	Fluoride	0.85	mg/l
28/06/2023 7:43 Fluoride 0.9 mg/l	28/06/2023 7:43	Fluoride	0.9	mg/l
4/07/2023 9:23 Fluoride 0.86 mg/l	4/07/2023 9:23	Fluoride	0.86	mg/l
12/07/2023 11:45 Fluoride 0.83 mg/l	12/07/2023 11:45	Fluoride	0.83	mg/l
20/07/2023 10:17 Fluoride 0.73 mg/l	20/07/2023 10:17	Fluoride	0.73	mg/l
26/07/2023 10:10 Fluoride 0.78 mg/l			0.78	mg/l
2/08/2023 23:47 Fluoride 0.8 mg/l	2/08/2023 23:47	Fluoride	0.8	mg/l
9/08/2023 10:15 Fluoride 0.78 mg/l			0.78	mg/l
15/08/2023 12:08 Fluoride 0.8 mg/l				0.
23/08/2023 10:07 Fluoride 0.72 mg/l			0.72	mg/l
29/08/2023 11:27 Fluoride 0.78 mg/l				-
6/09/2023 11:50 Fluoride 0.75 mg/l				-
12/09/2023 11:37 Fluoride 0.83 mg/l				
20/09/2023 12:35 Fluoride 0.82 mg/l				-
20/09/2023 12:35 Fluoride 0.82 mg/l				-
26/09/2023 12:23 Fluoride 0.87 mg/l				-
26/09/2023 12:23 Fluoride 0.87 mg/l				-
4/10/2023 11:39 Fluoride 0.81 mg/l				-
4/10/2023 11:39 Fluoride 0.81 mg/l				-
10/10/2023 11:54 Fluoride 0.05 mg/l				-
10/10/2023 11:54 Fluoride 0.05 mg/l				-
18/10/2023 9:37 Fluoride 0.83 mg/l				-
18/10/2023 9:37 Fluoride 0.83 mg/l				-
24/10/2023 11:58 Fluoride 0.91 mg/l				-
24/10/2023 11:58 Fluoride 0.91 mg/l				-
1/11/2023 14:01 Fluoride 0.91 mg/l	1/11/2023 14:01	Fluoride	0.91	mg/l

Te Marua Treated Water @ Pumping Station	1/11/2023 14:01 Fluoride	0.91 mg/l
Te Marua Treated Water @ Pumping Station	7/11/2023 11:16 Fluoride	0.9 mg/l
Te Marua Treated Water @ Pumping Station	7/11/2023 11:16 Fluoride	0.9 mg/l
Te Marua Treated Water @ Pumping Station	15/11/2023 8:03 Fluoride	0.81 mg/l
Te Marua Treated Water @ Pumping Station	21/11/2023 11:35 Fluoride	0.77 mg/l
Te Marua Treated Water @ Pumping Station	29/11/2023 10:26 Fluoride	0.78 mg/l
Te Marua Treated Water @ Pumping Station	5/12/2023 11:08 Fluoride	0.76 mg/l
Te Marua Treated Water @ Pumping Station	13/12/2023 11:15 Fluoride	0.8 mg/l
Te Marua Treated Water @ Pumping Station	19/12/2023 12:31 Fluoride	0.78 mg/l
Te Marua Treated Water @ Pumping Station	27/12/2023 7:39 Fluoride	0.83 mg/l
Te Marua Treated Water @ Pumping Station	27/12/2023 7:45 Fluoride	0.82 mg/l
Naenae Reservoir	8/01/2023 10:39 Fluoride	0.7 mg/l
Naenae Reservoir	11/01/2023 10:45 Fluoride	0.66 mg/l
Naenae Reservoir	17/01/2023 14:33 Fluoride	0.74 mg/l
Naenae Reservoir	17/01/2023 14:33 Fluoride	0.74 mg/l
Naenae Reservoir	17/01/2023 14:33 Fluoride	0.74 mg/l
Naenae Reservoir	25/01/2023 9:48 Fluoride	0.65 mg/l
Naenae Reservoir	31/01/2023 12:07 Fluoride	0.73 mg/l
Naenae Reservoir	16/02/2023 11:02 Fluoride	0.71 mg/l
Naenae Reservoir	22/02/2023 11:12 Fluoride	0.7 mg/l
Naenae Reservoir	28/02/2023 11:07 Fluoride	0.76 mg/l
Naenae Reservoir	8/03/2023 12:02 Fluoride	0.72 mg/l
Naenae Reservoir	14/03/2023 14:04 Fluoride	0.76 mg/l
Naenae Reservoir	22/03/2023 10:22 Fluoride	0.76 mg/l
Naenae Reservoir	28/03/2023 13:43 Fluoride	0.78 mg/l
Naenae Reservoir	5/04/2023 10:38 Fluoride	0.77 mg/l
Naenae Reservoir	11/04/2023 13:16 Fluoride	0.77 mg/l
Naenae Reservoir	19/04/2023 12:40 Fluoride	0.78 mg/l
Naenae Reservoir	26/04/2023 10:41 Fluoride	0.75 mg/l
Naenae Reservoir	3/05/2023 13:46 Fluoride	0.76 mg/l
Naenae Reservoir	17/05/2023 14:52 Fluoride	0.82 mg/l
Naenae Reservoir	23/05/2023 10:35 Fluoride	0.75 mg/l
Naenae Reservoir	31/05/2023 14:34 Fluoride	0.8 mg/l
Naenae Reservoir	6/06/2023 10:17 Fluoride	0.79 mg/l
Naenae Reservoir	14/06/2023 9:34 Fluoride	0.81 mg/l
Naenae Reservoir	20/06/2023 12:15 Fluoride	0.81 mg/l
Naenae Reservoir	28/06/2023 10:16 Fluoride	0.86 mg/l
Naenae Reservoir	4/07/2023 13:54 Fluoride	0.81 mg/l
Naenae Reservoir	12/07/2023 9:29 Fluoride	0.82 mg/l
Naenae Reservoir	18/07/2023 13:27 Fluoride	0.74 mg/l
Naenae Reservoir	26/07/2023 11:15 Fluoride	0.81 mg/l
Naenae Reservoir	26/07/2023 11:15 Fluoride	0.81 mg/l
Naenae Reservoir	1/08/2023 9:07 Fluoride	0.83 mg/l
Naenae Reservoir	9/08/2023 10:49 Fluoride	0.77 mg/l
Naenae Reservoir	15/08/2023 14:42 Fluoride	0.81 mg/l
Naenae Reservoir	23/08/2023 11:48 Fluoride	0.76 mg/l
Naenae Reservoir	29/08/2023 11:51 Fluoride	0.76 mg/l
Naenae Reservoir	6/09/2023 12:21 Fluoride	0.69 mg/l
Naenae Reservoir	12/09/2023 9:12 Fluoride	0.73 mg/l
Naenae Reservoir	20/09/2023 14:13 Fluoride	0.83 mg/l

Naenae Reservoir	20/09/2023 14:13 Fluoride	0.83 mg/l
Naenae Reservoir	26/09/2023 8:39 Fluoride	0.87 mg/l
Naenae Reservoir	26/09/2023 8:39 Fluoride	0.87 mg/l
Naenae Reservoir	4/10/2023 8:38 Fluoride	0.75 mg/l
Naenae Reservoir	4/10/2023 8:38 Fluoride	0.75 mg/l
Naenae Reservoir	10/10/2023 12:52 Fluoride	0.73 mg/l
Naenae Reservoir	10/10/2023 12:52 Fluoride	0.73 mg/l
Naenae Reservoir	18/10/2023 11:47 Fluoride	0.13 mg/l
Naenae Reservoir	18/10/2023 11:47 Fluoride	0.13 mg/l
Naenae Reservoir	24/10/2023 12:46 Fluoride	0.09 mg/l
Naenae Reservoir	24/10/2023 12:46 Fluoride	0.09 mg/l
Naenae Reservoir	1/11/2023 14:39 Fluoride	0.87 mg/l
Naenae Reservoir	1/11/2023 14:39 Fluoride	0.87 mg/l
Naenae Reservoir	7/11/2023 14:45 Fluoride	0.89 mg/l
Naenae Reservoir	7/11/2023 14:45 Fluoride	0.89 mg/l
Naenae Reservoir	15/11/2023 10:45 Fluoride	0.38 mg/l
Naenae Reservoir	21/11/2023 12:19 Fluoride	0.78 mg/l
Naenae Reservoir	29/11/2023 11:17 Fluoride	0.79 mg/l
Naenae Reservoir	5/12/2023 14:08 Fluoride	0.82 mg/l
Naenae Reservoir	13/12/2023 12:01 Fluoride	0.73 mg/l
Naenae Reservoir	19/12/2023 14:35 Fluoride	0.76 mg/l
Naenae Reservoir	27/12/2023 8:06 Fluoride	0.89 mg/l
Wainuiomata Treated Water @ Gate House	4/01/2023 11:42 Fluoride	0.76 mg/l
Wainuiomata Treated Water @ Gate House	11/01/2023 11:57 Fluoride	0.66 mg/l
Wainuiomata Treated Water @ Gate House	17/01/2023 13:45 Fluoride	0.82 mg/l
Wainuiomata Treated Water @ Gate House	25/01/2023 11:55 Fluoride	0.69 mg/l
Wainuiomata Treated Water @ Gate House	31/01/2023 11:14 Fluoride	0.76 mg/l
Wainuiomata Treated Water @ Gate House	8/02/2023 10:51 Fluoride	0.88 mg/l
Wainuiomata Treated Water @ Gate House	14/02/2023 9:48 Fluoride	0.77 mg/l
Wainuiomata Treated Water @ Gate House	22/02/2023 8:41 Fluoride	0.79 mg/l
Wainuiomata Treated Water @ Gate House	28/02/2023 10:21 Fluoride	0.05 mg/l
Wainuiomata Treated Water @ Gate House	8/03/2023 8:44 Fluoride	0.61 mg/l
Wainuiomata Treated Water @ Gate House	15/03/2023 10:50 Fluoride	0.66 mg/l
Wainuiomata Treated Water @ Gate House	22/03/2023 8:53 Fluoride	0.7 mg/l
Wainuiomata Treated Water @ Gate House	28/03/2023 14:04 Fluoride	0.74 mg/l
Wainuiomata Treated Water @ Gate House	5/04/2023 8:43 Fluoride	0.67 mg/l
Wainuiomata Treated Water @ Gate House	11/04/2023 12:27 Fluoride	0.66 mg/l
Wainuiomata Treated Water @ Gate House	19/04/2023 10:16 Fluoride	0.64 mg/l
Wainuiomata Treated Water @ Gate House	3/05/2023 9:18 Fluoride	0.68 mg/l
Wainuiomata Treated Water @ Gate House	9/05/2023 12:09 Fluoride	0.75 mg/l
Wainuiomata Treated Water @ Gate House	17/05/2023 11:20 Fluoride	0.68 mg/l
Wainuiomata Treated Water @ Gate House	23/05/2023 13:56 Fluoride	0.6 mg/l
Wainuiomata Treated Water @ Gate House	31/05/2023 8:25 Fluoride	0.74 mg/l
Wainuiomata Treated Water @ Gate House	6/06/2023 12:42 Fluoride	0.75 mg/l
Wainuiomata Treated Water @ Gate House	14/06/2023 10:21 Fluoride	0.74 mg/l
Wainuiomata Treated Water @ Gate House	20/06/2023 9:41 Fluoride	0.73 mg/l
Wainuiomata Treated Water @ Gate House	28/06/2023 11:14 Fluoride	0.77 mg/l
Wainuiomata Treated Water @ Gate House	6/07/2023 12:40 Fluoride	0.12 mg/l
Wainuiomata Treated Water @ Gate House	12/07/2023 14:08 Fluoride	0.68 mg/l
Wainuiomata Treated Water @ Gate House	26/07/2023 8:47 Fluoride	0.1 mg/l

Wainuiomata Treated Water @ Gate House Thorndon Pumping Station - ex Turbidity Meter Thorndon Pumping Station - ex Turbidity Meter

1/08/2023 9:09	Fluoride	0.66 mg/l
15/08/2023 13:14	Fluoride	0.67 mg/l
23/08/2023 9:08	Fluoride	0.65 mg/l
29/08/2023 10:51	Fluoride	0.67 mg/l
6/09/2023 9:28	Fluoride	0.63 mg/l
12/09/2023 12:13	Fluoride	0.77 mg/l
20/09/2023 15:34	Fluoride	0.82 mg/l
20/09/2023 15:34	Fluoride	0.82 mg/l
26/09/2023 11:05	Fluoride	0.83 mg/l
26/09/2023 11:05	Fluoride	0.83 mg/l
4/10/2023 10:35	Fluoride	0.77 mg/l
4/10/2023 10:35		0.77 mg/l
10/10/2023 9:41		0.78 mg/l
10/10/2023 9:41		0.78 mg/l
18/10/2023 13:52		0.85 mg/l
18/10/2023 13:52		0.85 mg/l
24/10/2023 10:50		0.97 mg/l
24/10/2023 10:50		0.97 mg/l
1/11/2023 10:31		0.75 mg/l
1/11/2023 10:31		0.75 mg/l
7/11/2023 10:51		0.75 mg/l
7/11/2023 10:51		0.75 mg/l
15/11/2023 12:23		0.71 mg/l
21/11/2023 14:40		0.74 mg/l
29/11/2023 12:08		0.75 mg/l
13/12/2023 14:00		0.73 mg/l
19/12/2023 14:37		0.74 mg/l
27/12/2023 8:32		0.84 mg/l
27/12/2023 8:33		0.83 mg/l
8/01/2023 8:14		0.68 mg/l
12/01/2023 14:38		0.61 mg/l
22/01/2023 9:12		0.65 mg/l
26/01/2023 15:34		0.81 mg/l
30/01/2023 9:55		0.24 mg/l
11/02/2023 10:15		0.85 mg/l
19/02/2023 12:41		0.79 mg/l
21/02/2023 14:56		0.75 mg/l
5/03/2023 11:03		0.73 mg/l
9/03/2023 11:26		0.75 mg/l
19/03/2023 11:30		0.76 mg/l
23/03/2023 11:53		0.79 mg/l
29/03/2023 14:15		0.83 mg/l
6/04/2023 14:21		0.7 mg/l
12/04/2023 10:45		0.83 mg/l
20/04/2023 10:43		0.79 mg/l
29/04/2023 9:16		0.85 mg/l
6/05/2023 8:52 14/05/2023 10:59		0.82 mg/l
20/05/2023 10:59		0.73 mg/l 0.75 mg/l
28/05/2023 14:13		0.75 mg/l
20/03/2023 14.13	i laonae	5.75 mg/1

Thorndon Pumping Station - ex Turbidity Meter	31/05/2023 9:18 Fluoride	0.79 mg/l
Thorndon Pumping Station - ex Turbidity Meter	11/06/2023 11:31 Fluoride	0.81 mg/l
Thorndon Pumping Station - ex Turbidity Meter	17/06/2023 14:20 Fluoride	0.81 mg/l
Thorndon Pumping Station - ex Turbidity Meter	19/06/2023 11:41 Fluoride	0.82 mg/l
Thorndon Pumping Station - ex Turbidity Meter	28/06/2023 13:55 Fluoride	0.84 mg/l
Thorndon Pumping Station - ex Turbidity Meter	16/07/2023 10:42 Fluoride	0.7 mg/l
Thorndon Pumping Station - ex Turbidity Meter	19/07/2023 14:37 Fluoride	0.85 mg/l
Thorndon Pumping Station - ex Turbidity Meter	27/07/2023 9:17 Fluoride	0.76 mg/l
Thorndon Pumping Station - ex Turbidity Meter	2/08/2023 11:55 Fluoride	0.8 mg/l
Thorndon Pumping Station - ex Turbidity Meter	24/08/2023 8:54 Fluoride	0.38 mg/l
Thorndon Pumping Station - ex Turbidity Meter	28/08/2023 14:24 Fluoride	0.81 mg/l
Thorndon Pumping Station - ex Turbidity Meter	9/09/2023 7:33 Fluoride	0.79 mg/l
Thorndon Pumping Station - ex Turbidity Meter	13/09/2023 12:35 Fluoride	0.8 mg/l
Thorndon Pumping Station - ex Turbidity Meter	23/09/2023 11:05 Fluoride	0.83 mg/l
Thorndon Pumping Station - ex Turbidity Meter	23/09/2023 11:05 Fluoride	0.83 mg/l
Thorndon Pumping Station - ex Turbidity Meter	29/09/2023 8:40 Fluoride	0.84 mg/l
Thorndon Pumping Station - ex Turbidity Meter	29/09/2023 8:40 Fluoride	0.84 mg/l
Thorndon Pumping Station - ex Turbidity Meter	3/10/2023 11:42 Fluoride	0.8 mg/l
Thorndon Pumping Station - ex Turbidity Meter	3/10/2023 11:42 Fluoride	0.8 mg/l
Thorndon Pumping Station - ex Turbidity Meter	11/10/2023 12:40 Fluoride	0.78 mg/l
Thorndon Pumping Station - ex Turbidity Meter	11/10/2023 12:40 Fluoride	0.78 mg/l
Thorndon Pumping Station - ex Turbidity Meter	17/10/2023 12:17 Fluoride	0.88 mg/l
Thorndon Pumping Station - ex Turbidity Meter	17/10/2023 12:17 Fluoride	0.88 mg/l
Thorndon Pumping Station - ex Turbidity Meter	25/10/2023 14:25 Fluoride	0.24 mg/l
Thorndon Pumping Station - ex Turbidity Meter	25/10/2023 14:25 Fluoride	0.24 mg/l
Thorndon Pumping Station - ex Turbidity Meter	31/10/2023 10:21 Fluoride	0.82 mg/l
Thorndon Pumping Station - ex Turbidity Meter	31/10/2023 10:21 Fluoride	0.82 mg/l
Thorndon Pumping Station - ex Turbidity Meter	8/11/2023 12:02 Fluoride	0.78 mg/l
Thorndon Pumping Station - ex Turbidity Meter	8/11/2023 12:02 Fluoride	0.78 mg/l
Thorndon Pumping Station - ex Turbidity Meter	16/11/2023 9:03 Fluoride	0.76 mg/l
Thorndon Pumping Station - ex Turbidity Meter	22/11/2023 11:05 Fluoride	0.72 mg/l
Thorndon Pumping Station - ex Turbidity Meter	30/11/2023 11:25 Fluoride	0.66 mg/l
Thorndon Pumping Station - ex Turbidity Meter	8/12/2023 12:01 Fluoride	0.74 mg/l
Thorndon Pumping Station - ex Turbidity Meter	14/12/2023 8:37 Fluoride	0.73 mg/l
Thorndon Pumping Station - ex Turbidity Meter	20/12/2023 11:01 Fluoride	0.73 mg/l
Thorndon Pumping Station - ex Turbidity Meter	28/12/2023 9:15 Fluoride	0.72 mg/l
Karori - ex Turbidity Meter	8/01/2023 7:54 Fluoride	0.69 mg/l
Karori - ex Turbidity Meter	12/01/2023 12:48 Fluoride	0.66 mg/l
Karori - ex Turbidity Meter	22/01/2023 8:01 Fluoride	0.78 mg/l
Karori - ex Turbidity Meter	26/01/2023 12:17 Fluoride	0.79 mg/l
Karori - ex Turbidity Meter	30/01/2023 10:44 Fluoride	0.25 mg/l
Karori - ex Turbidity Meter	11/02/2023 10:54 Fluoride	0.76 mg/l
Karori - ex Turbidity Meter	19/02/2023 12:18 Fluoride	0.74 mg/l
Karori - ex Turbidity Meter	21/02/2023 12:15 Fluoride	0.76 mg/l
Karori - ex Turbidity Meter	5/03/2023 10:27 Fluoride	0.71 mg/l
Karori - ex Turbidity Meter	9/03/2023 8:57 Fluoride	0.73 mg/l
Karori - ex Turbidity Meter	19/03/2023 10:32 Fluoride 23/03/2023 11:39 Fluoride	0.75 mg/l
Karori - ex Turbidity Meter Karori - ex Turbidity Meter	23/03/2023 11:39 Fluoride 29/03/2023 14:15 Fluoride	0.79 mg/l 0.78 mg/l
Karori - ex Turbidity Meter	6/04/2023 10:30 Fluoride	0.78 mg/l 0.75 mg/l
Report - CA TUIDIUILY MELEI	0/04/2023 10.30 FIGULINE	118/1

Karori - ex Turbidity Meter
Karori - ex Turbidity Meter
, Karori - ex Turbidity Meter
, Karori - ex Turbidity Meter
Karori - ex Turbidity Meter
Karori - ex Turbidity Meter
Karori - ex Turbidity Meter
Karori - ex Turbidity Meter
Karori - ex Turbidity Meter
Waterloo Treated Water - Naenae Main
Watchied Heaten Watch Nachae Main

12/04/2023 11:34 Fluoride	0.75 mg/l
20/04/2023 10:59 Fluoride	0.75 mg/l
29/04/2023 9:05 Fluoride	0.82 mg/l
6/05/2023 8:30 Fluoride	0.8 mg/l
14/05/2023 10:38 Fluoride	0.76 mg/l
20/05/2023 11:20 Fluoride	0.78 mg/l
28/05/2023 12:22 Fluoride	0.79 mg/l
31/05/2023 10:36 Fluoride	0.82 mg/l
11/06/2023 10:38 Fluoride	0.79 mg/l
17/06/2023 10:49 Fluoride	0.8 mg/l
19/06/2023 9:59 Fluoride	0.81 mg/l
28/06/2023 12:36 Fluoride	0.8 mg/l
16/07/2023 10:10 Fluoride	0.74 mg/l
21/07/2023 10:10 Fluoride	0.91 mg/l
25/07/2023 10:04 Fluoride	0.81 mg/l
2/08/2023 9:36 Fluoride	0.75 mg/l
22/08/2023 13:47 Fluoride	0.76 mg/l
28/08/2023 11:31 Fluoride	0.8 mg/l
9/09/2023 9:12 Fluoride	0.78 mg/l
13/09/2023 9:19 Fluoride	0.82 mg/l
24/09/2023 10:33 Fluoride	0.81 mg/l
24/09/2023 10:33 Fluoride	0.81 mg/l
29/09/2023 11:38 Fluoride	0.82 mg/l
29/09/2023 11:38 Fluoride	0.82 mg/l
3/10/2023 9:40 Fluoride	0.83 mg/l
3/10/2023 9:40 Fluoride	0.83 mg/l
11/10/2023 10:44 Fluoride	0.58 mg/l
11/10/2023 10:44 Fluoride	0.58 mg/l
17/10/2023 9:31 Fluoride	0.21 mg/l
17/10/2023 9:31 Fluoride	0.21 mg/l
25/10/2023 10:16 Fluoride	0.84 mg/l
25/10/2023 10:16 Fluoride	0.84 mg/l
31/10/2023 8:55 Fluoride	0.87 mg/l
31/10/2023 8:55 Fluoride	0.87 mg/l
8/11/2023 8:20 Fluoride	0.85 mg/l
8/11/2023 8:20 Fluoride	0.85 mg/l
14/11/2023 11:05 Fluoride	0.81 mg/l
14/11/2023 11:05 Fluoride	0.81 mg/l
22/11/2023 10:43 Fluoride	0.7 mg/l
30/11/2023 13:00 Fluoride	0.69 mg/l
8/12/2023 8:47 Fluoride	0.72 mg/l
14/12/2023 10:25 Fluoride	0.76 mg/l
20/12/2023 11:44 Fluoride	0.8 mg/l
28/12/2023 11:10 Fluoride	0.73 mg/l
4/01/2023 12:24 Fluoride	0.71 mg/l
11/01/2023 11:14 Fluoride	0.64 mg/l
17/01/2023 14:52 Fluoride	0.74 mg/l
25/01/2023 10:06 Fluoride	0.61 mg/l
31/01/2023 10:27 Fluoride	0.72 mg/l
10/02/2023 15:59 Fluoride	0.72 mg/l
10/02/2023 13.33 Hudhue	0.77 IIIg/I

Waterloo Treated Water - Naenae Main Gear Island Treated Water @ Outlet Gear Island Treated Water @ Outlet

16/02/2023 14:24 Fluoride	0.7 mg/l
22/02/2023 11:34 Fluoride	0.73 mg/l
28/02/2023 11:18 Fluoride	0.76 mg/l
8/03/2023 12:28 Fluoride	0.72 mg/l
15/03/2023 11:32 Fluoride	0.08 mg/l
22/03/2023 10:40 Fluoride	0.73 mg/l
28/03/2023 13:24 Fluoride	0.08 mg/l
5/04/2023 10:59 Fluoride	0.76 mg/l
11/04/2023 12:49 Fluoride	0.81 mg/l
19/04/2023 13:03 Fluoride	0.72 mg/l
9/05/2023 11:06 Fluoride	0.65 mg/l
17/05/2023 12:56 Fluoride	0.79 mg/l
17/05/2023 12:57 Fluoride	0.79 mg/l
23/05/2023 10:58 Fluoride	0.77 mg/l
31/05/2023 14:54 Fluoride	0.82 mg/l
6/06/2023 15:33 Fluoride	0.82 mg/l
14/06/2023 13:32 Fluoride	0.79 mg/l
20/06/2023 11:57 Fluoride	0.8 mg/l
28/06/2023 10:29 Fluoride	0.86 mg/l
4/07/2023 13:23 Fluoride	0.79 mg/l
13/07/2023 11:44 Fluoride	0.82 mg/l
26/07/2023 13:49 Fluoride	0.8 mg/l
2/08/2023 10:02 Fluoride	0.86 mg/l
9/08/2023 11:02 Fluoride	0.79 mg/l
4/01/2023 10:55 Fluoride	0.27 mg/l
11/01/2023 10:02 Fluoride	0.23 mg/l
17/01/2023 15:57 Fluoride	0.31 mg/l
25/01/2023 10:33 Fluoride	0.38 mg/l
31/01/2023 14:42 Fluoride	0.11 mg/l
10/02/2023 10:32 Fluoride	0.23 mg/l
16/02/2023 14:58 Fluoride	0.09 mg/l
22/02/2023 14:20 Fluoride	0.41 mg/l
28/02/2023 14:42 Fluoride	0.47 mg/l
8/03/2023 14:04 Fluoride	0.3 mg/l
15/03/2023 12:04 Fluoride	0.23 mg/l
22/03/2023 12:29 Fluoride	0.09 mg/l
28/03/2023 10:02 Fluoride	0.34 mg/l
5/04/2023 12:22 Fluoride	0.42 mg/l
11/04/2023 9:55 Fluoride	0.52 mg/l
19/04/2023 11:33 Fluoride	0.49 mg/l
3/05/2023 12:55 Fluoride	0.37 mg/l
9/05/2023 13:47 Fluoride	0.36 mg/l
17/05/2023 12:08 Fluoride	0.42 mg/l
23/05/2023 12:39 Fluoride	0.38 mg/l
1/06/2023 13:07 Fluoride	0.37 mg/l
6/06/2023 11:02 Fluoride	0.39 mg/l
14/06/2023 14:15 Fluoride	0.37 mg/l
20/06/2023 14:48 Fluoride	0.09 mg/l
28/06/2023 13:00 Fluoride	0.51 mg/l
4/07/2023 14:20 Fluoride	0.4 mg/l

Gear Island Treated Water @ Outlet Haywards Reservoir Haywards Reservoir

13/07/2023 11:21 Fluoride	0.46 mg/l
26/07/2023 13:16 Fluoride	0.19 mg/l
1/08/2023 13:58 Fluoride	0.13 mg/l
9/08/2023 12:42 Fluoride	0.32 mg/l
15/08/2023 15:03 Fluoride	0.41 mg/l
25/08/2023 9:54 Fluoride	0.35 mg/l
29/08/2023 14:52 Fluoride	0.45 mg/l
6/09/2023 14:02 Fluoride	0.46 mg/l
12/09/2023 13:49 Fluoride	0.45 mg/l
20/09/2023 8:09 Fluoride	0.2 mg/l
20/09/2023 8:09 Fluoride	0.2 mg/l
26/09/2023 9:39 Fluoride	0.47 mg/l
26/09/2023 9:39 Fluoride	0.47 mg/l
4/10/2023 13:23 Fluoride	0.5 mg/l
4/10/2023 13:23 Fluoride	0.5 mg/l
10/10/2023 13:45 Fluoride	0.38 mg/l
10/10/2023 13:45 Fluoride	0.38 mg/l
20/10/2023 8:35 Fluoride	0.51 mg/l
20/10/2023 8:35 Fluoride	0.51 mg/l
24/10/2023 14:32 Fluoride	0.64 mg/l
24/10/2023 14:32 Fluoride	0.64 mg/l
1/11/2023 9:01 Fluoride	0.48 mg/l
1/11/2023 9:01 Fluoride	0.48 mg/l
7/11/2023 8:10 Fluoride	0.47 mg/l
7/11/2023 8:10 Fluoride	0.47 mg/l
15/11/2023 14:19 Fluoride	0.09 mg/l
21/11/2023 13:56 Fluoride	0.23 mg/l
29/11/2023 13:42 Fluoride	0.34 mg/l
5/12/2023 11:16 Fluoride	0.25 mg/l
13/12/2023 12:43 Fluoride	0.1 mg/l
21/12/2023 8:23 Fluoride	0.38 mg/l
27/12/2023 9:47 Fluoride	0.42 mg/l
4/01/2023 9:34 Fluoride	0.64 mg/l
11/01/2023 11:31 Fluoride	0.63 mg/l
17/01/2023 9:35 Fluoride	0.7 mg/l
25/01/2023 14:26 Fluoride	0.72 mg/l
31/01/2023 10:13 Fluoride	0.7 mg/l
14/02/2023 14:09 Fluoride	0.76 mg/l
22/02/2023 8:55 Fluoride	0.76 mg/l
28/02/2023 9:33 Fluoride	0.78 mg/l
8/03/2023 9:46 Fluoride	0.76 mg/l
14/03/2023 8:36 Fluoride	0.81 mg/l
22/03/2023 15:42 Fluoride	0.77 mg/l
28/03/2023 8:51 Fluoride	0.78 mg/l
5/04/2023 10:34 Fluoride	0.75 mg/l
11/04/2023 9:24 Fluoride	0.79 mg/l
19/04/2023 11:00 Fluoride	0.78 mg/l
26/04/2023 9:23 Fluoride	0.76 mg/l
3/05/2023 9:40 Fluoride	0.75 mg/l
17/05/2023 9:20 Fluoride	0.82 mg/l

Haywards Reservoir Havwards Reservoir Waterloo Treated Water @ Outlet Waterloo Treated Water @ Outlet

23/05/2023 9:11 Fluoride	0.8 mg/l
31/05/2023 11:16 Fluoride	0.71 mg/l
6/06/2023 11:53 Fluoride	0.86 mg/l
14/06/2023 10:22 Fluoride	0.86 mg/l
20/06/2023 9:28 Fluoride	0.84 mg/l
28/06/2023 9:48 Fluoride	0.87 mg/l
4/07/2023 12:08 Fluoride	0.87 mg/l
12/07/2023 11:00 Fluoride	0.83 mg/l
18/07/2023 12:35 Fluoride	0.83 mg/l
26/07/2023 9:13 Fluoride	0.78 mg/l
1/08/2023 10:02 Fluoride	0.73 mg/l
9/08/2023 13:28 Fluoride	0.77 mg/l
15/08/2023 9:14 Fluoride	0.79 mg/l
23/08/2023 9:12 Fluoride	0.72 mg/l
29/08/2023 10:52 Fluoride	0.78 mg/l
6/09/2023 14:29 Fluoride	0.74 mg/l
12/09/2023 10:22 Fluoride	0.83 mg/l
20/09/2023 13:57 Fluoride	0.84 mg/l
26/09/2023 11:48 Fluoride	0.81 mg/l
4/10/2023 10:07 Fluoride	0.82 mg/l
10/10/2023 10:55 Fluoride	0.05 mg/l
18/10/2023 11:17 Fluoride	0.79 mg/l
24/10/2023 10:06 Fluoride	0.9 mg/l
1/11/2023 11:22 Fluoride	0.89 mg/l
7/11/2023 9:06 Fluoride	0.89 mg/l
7/12/2023 13:24 Fluoride	0.69 mg/l
13/12/2023 13:54 Fluoride	0.84 mg/l
19/12/2023 10:18 Fluoride	0.79 mg/l
27/12/2023 9:50 Fluoride	0.83 mg/l
15/08/2023 14:14 Fluoride	0.11 mg/l
25/08/2023 10:43 Fluoride	0.1 mg/l
29/08/2023 11:33 Fluoride	0.09 mg/l
6/09/2023 11:45 Fluoride	0.09 mg/l
12/09/2023 9:00 Fluoride	0.09 mg/l
20/09/2023 14:27 Fluoride	0.09 mg/l
20/09/2023 14:27 Fluoride	0.09 mg/l
26/09/2023 8:15 Fluoride	0.1 mg/l
26/09/2023 8:15 Fluoride	0.1 mg/l
4/10/2023 9:12 Fluoride	0.09 mg/l
4/10/2023 9:12 Fluoride	0.09 mg/l
10/10/2023 13:20 Fluoride	0.08 mg/l
10/10/2023 13:20 Fluoride	0.08 mg/l
18/10/2023 12:06 Fluoride	0.1 mg/l
18/10/2023 12:06 Fluoride	0.1 mg/l
24/10/2023 12:19 Fluoride	0.08 mg/l
24/10/2023 12:19 Fluoride	0.08 mg/l
1/11/2023 15:12 Fluoride	0.09 mg/l
1/11/2023 15:12 Fluoride	0.09 mg/l
7/11/2023 8:19 Fluoride	0.1 mg/l
7/11/2023 8:19 Fluoride	0.1 mg/l

Waterloo Treated Water @ Outlet 1050 main Downstream of Gear Island 1050 main Downstream of Gear Island

15/11/2023 11:42 Fluoride	0.09 mg/l
21/11/2023 13:30 Fluoride	0.08 mg/l
29/11/2023 12:04 Fluoride	0.09 mg/l
7/12/2023 11:31 Fluoride	0.08 mg/l
13/12/2023 11:08 Fluoride	0.75 mg/l
19/12/2023 8:16 Fluoride	0.09 mg/l
27/12/2023 7:50 Fluoride	0.89 mg/l
4/01/2023 10:53 Fluoride	0.67 mg/l
11/01/2023 9:58 Fluoride	0.63 mg/l
17/01/2023 15:56 Fluoride	0.76 mg/l
17/01/2023 15:56 Fluoride	0.76 mg/l
17/01/2023 15:56 Fluoride	0.76 mg/l
25/01/2023 10:30 Fluoride	0.8 mg/l
31/01/2023 14:42 Fluoride	0.72 mg/l
16/02/2023 15:07 Fluoride	0.09 mg/l
22/02/2023 14:16 Fluoride	0.41 mg/l
28/02/2023 15:17 Fluoride	0.71 mg/l
8/03/2023 14:05 Fluoride	0.3 mg/l
15/03/2023 12:04 Fluoride	0.63 mg/l
22/03/2023 12:25 Fluoride	0.79 mg/l
28/03/2023 9:58 Fluoride	0.79 mg/l
5/04/2023 12:15 Fluoride	0.78 mg/l
11/04/2023 9:57 Fluoride	0.73 mg/l
19/04/2023 11:34 Fluoride	0.74 mg/l
26/04/2023 13:46 Fluoride	0.19 mg/l
3/05/2023 12:58 Fluoride	0.4 mg/l
17/05/2023 12:06 Fluoride	0.81 mg/l
23/05/2023 12:40 Fluoride	0.38 mg/l
1/06/2023 13:05 Fluoride	0.37 mg/l
6/06/2023 10:59 Fluoride	0.22 mg/l
14/06/2023 14:11 Fluoride	0.4 mg/l
20/06/2023 14:46 Fluoride	0.81 mg/l
28/06/2023 13:02 Fluoride	0.51 mg/l
4/07/2023 14:34 Fluoride	0.77 mg/l
13/07/2023 11:19 Fluoride	0.66 mg/l
18/07/2023 13:33 Fluoride	0.45 mg/l
26/07/2023 13:01 Fluoride	0.84 mg/l
26/07/2023 13:01 Fluoride	0.84 mg/l
1/08/2023 13:51 Fluoride	0.42 mg/l
9/08/2023 12:42 Fluoride	0.65 mg/l
15/08/2023 15:01 Fluoride	0.73 mg/l
25/08/2023 9:58 Fluoride	0.81 mg/l
29/08/2023 14:55 Fluoride	0.76 mg/l
6/09/2023 13:52 Fluoride	0.68 mg/l
12/09/2023 14:06 Fluoride	0.8 mg/l
20/09/2023 8:07 Fluoride	0.84 mg/l
20/09/2023 8:07 Fluoride	0.84 mg/l
26/09/2023 10:27 Fluoride	0.82 mg/l
26/09/2023 10:27 Fluoride	0.82 mg/l
5/10/2023 15:05 Fluoride	0.81 mg/l

1050 main Downstream of Gear Island Pukerua Bay Reservoir Pukerua Bay Reservoir

5/10/2023 15:05 Fluoride	0.81 mg/l
10/10/2023 13:53 Fluoride	0.77 mg/l
10/10/2023 13:53 Fluoride	0.77 mg/l
20/10/2023 8:38 Fluoride	0.82 mg/l
20/10/2023 8:38 Fluoride	0.82 mg/l
24/10/2023 14:33 Fluoride	0.91 mg/l
24/10/2023 14:33 Fluoride	0.91 mg/l
1/11/2023 9:00 Fluoride	0.81 mg/l
1/11/2023 9:00 Fluoride	0.81 mg/l
7/11/2023 8:12 Fluoride	0.77 mg/l
7/11/2023 8:12 Fluoride	0.77 mg/l
15/11/2023 14:30 Fluoride	0.76 mg/l
21/11/2023 13:54 Fluoride	0.45 mg/l
29/11/2023 13:43 Fluoride	0.55 mg/l
5/12/2023 11:15 Fluoride	0.58 mg/l
13/12/2023 12:45 Fluoride	0.68 mg/l
21/12/2023 8:24 Fluoride	0.86 mg/l
27/12/2023 9:56 Fluoride	0.87 mg/l
4/01/2023 12:31 Fluoride	0.63 mg/l
12/01/2023 10:33 Fluoride	0.64 mg/l
20/01/2023 8:39 Fluoride	0.57 mg/l
24/01/2023 13:18 Fluoride	0.75 mg/l
30/01/2023 12:54 Fluoride	0.72 mg/l
9/02/2023 13:22 Fluoride	0.78 mg/l
17/02/2023 9:56 Fluoride	0.74 mg/l
21/02/2023 8:35 Fluoride	0.73 mg/l
27/02/2023 13:26 Fluoride	0.78 mg/l
7/03/2023 12:55 Fluoride	0.73 mg/l
15/03/2023 8:48 Fluoride	0.81 mg/l
21/03/2023 11:01 Fluoride	0.76 mg/l
27/03/2023 8:40 Fluoride	0.75 mg/l
6/04/2023 8:59 Fluoride	0.75 mg/l
12/04/2023 10:15 Fluoride	0.77 mg/l
18/04/2023 13:38 Fluoride	0.79 mg/l
24/04/2023 11:46 Fluoride	0.74 mg/l
4/05/2023 12:59 Fluoride	0.76 mg/l
10/05/2023 13:25 Fluoride	0.74 mg/l
18/05/2023 10:38 Fluoride	0.79 mg/l
22/05/2023 13:07 Fluoride	0.04 mg/l
30/05/2023 11:59 Fluoride	0.84 mg/l
5/06/2023 10:33 Fluoride	0.78 mg/l
13/06/2023 11:38 Fluoride	0.85 mg/l
19/06/2023 10:46 Fluoride	0.84 mg/l
27/06/2023 9:54 Fluoride	0.86 mg/l
11/07/2023 10:27 Fluoride	0.84 mg/l
11/07/2023 10:27 Fluoride	0.84 mg/l
17/07/2023 9:50 Fluoride	0.81 mg/l
25/07/2023 14:13 Fluoride	0.44 mg/l
2/08/2023 10:51 Fluoride	0.75 mg/l
10/08/2023 12:34 Fluoride	0.76 mg/l

Pukerua Bay Reservoir Rahui Reservoir

22/08/2023 11:49 Fluoride	0.76 mg/l
28/08/2023 13:36 Fluoride	0.81 mg/l
5/09/2023 13:17 Fluoride	0.77 mg/l
11/09/2023 13:29 Fluoride	0.83 mg/l
19/09/2023 11:14 Fluoride	0.86 mg/l
19/09/2023 11:14 Fluoride	0.86 mg/l
25/09/2023 14:15 Fluoride	0.82 mg/l
25/09/2023 14:15 Fluoride	0.82 mg/l
5/10/2023 9:39 Fluoride	0.85 mg/l
5/10/2023 9:39 Fluoride	0.85 mg/l
13/10/2023 11:42 Fluoride	0.06 mg/l
13/10/2023 11:42 Fluoride	0.06 mg/l
17/10/2023 11:08 Fluoride	0.27 mg/l
17/10/2023 11:08 Fluoride	0.27 mg/l
25/10/2023 13:50 Fluoride	0.86 mg/l
25/10/2023 13:50 Fluoride	0.86 mg/l
31/10/2023 11:58 Fluoride	0.87 mg/l
31/10/2023 11:58 Fluoride	0.87 mg/l
6/11/2023 10:23 Fluoride	0.87 mg/l
6/11/2023 10:23 Fluoride	0.87 mg/l
14/11/2023 13:10 Fluoride	0.83 mg/l
14/11/2023 13:10 Fluoride	0.83 mg/l
20/11/2023 12:30 Fluoride	0.75 mg/l
28/11/2023 10:54 Fluoride	0.82 mg/l
4/12/2023 13:02 Fluoride	0.82 mg/l
12/12/2023 9:51 Fluoride	0.8 mg/l
18/12/2023 11:46 Fluoride	0.79 mg/l
28/12/2023 12:52 Fluoride	0.82 mg/l
8/01/2023 9:32 Fluoride	0.1 mg/l
11/01/2023 9:28 Fluoride	0.1 mg/l
17/01/2023 9:55 Fluoride	0.1 mg/l
17/01/2023 9:55 Fluoride	0.1 mg/l
17/01/2023 9:55 Fluoride	0.1 mg/l
25/01/2023 9:24 Fluoride	0.08 mg/l
31/01/2023 8:54 Fluoride	0.08 mg/l
8/02/2023 16:00 Fluoride	0.09 mg/l
16/02/2023 13:22 Fluoride	0.09 mg/l
22/02/2023 12:44 Fluoride	0.09 mg/l
28/02/2023 14:10 Fluoride	0.08 mg/l
8/03/2023 12:51 Fluoride	0.09 mg/l
18/03/2023 14:40 Fluoride	0.08 mg/l
22/03/2023 11:00 Fluoride	0.09 mg/l
28/03/2023 11:04 Fluoride	0.09 mg/l
5/04/2023 9:13 Fluoride	0.09 mg/l 0.1 mg/l
11/04/2023 14:29 Fluoride	0.1 mg/l 0.14 mg/l
19/04/2023 14:25 Fluoride	0.14 mg/l 0.1 mg/l
26/04/2023 14:11 Fluoride	0.1 mg/l 0.09 mg/l
3/05/2023 13:13 Fluoride	0.09 mg/l
17/05/2023 8:50 Fluoride	0.09 mg/l 0.1 mg/l
23/05/2023 11:35 Fluoride	0.1 mg/l 0.09 mg/l
25/05/2025 11.55 Flublide	

Rahui Reservoir Ngauranga Res Outlet Ngauranga Res Outlet

31/05/2023 10:44 Fluoride	-
6/06/2023 9:45 Fluoride	0.
14/06/2023 12:12 Fluoride	e 0.1 mg/l
20/06/2023 14:18 Fluoride	e 0.1 mg/l
28/06/2023 12:32 Fluoride	e 0.1 mg/l
4/07/2023 12:37 Fluoride	e 0.1 mg/l
12/07/2023 8:00 Fluoride	e 0.1 mg/l
18/07/2023 10:30 Fluoride	e 0.1 mg/l
26/07/2023 12:30 Fluoride	e 0.09 mg/l
26/07/2023 12:30 Fluoride	e 0.09 mg/l
1/08/2023 14:33 Fluoride	e 0.09 mg/l
9/08/2023 10:04 Fluoride	e 0.1 mg/l
16/08/2023 14:56 Fluoride	e 0.09 mg/l
21/08/2023 15:06 Fluoride	e 0.13 mg/l
29/08/2023 14:29 Fluoride	e 0.09 mg/l
6/09/2023 9:27 Fluoride	e 0.09 mg/l
12/09/2023 8:41 Fluoride	-
20/09/2023 12:36 Fluoride	-
20/09/2023 12:36 Fluoride	-
26/09/2023 12:37 Fluoride	0.
26/09/2023 12:37 Fluoride	-
4/10/2023 14:44 Fluoride	-
4/10/2023 14:44 Fluoride	-
10/10/2023 11:59 Fluoride	-
10/10/2023 11:59 Fluoride	-
20/10/2023 8:00 Fluoride	-
20/10/2023 8:00 Fluoride	
24/10/2023 14:07 Fluoride	0.
24/10/2023 14:07 Fluoride	<u> </u>
1/11/2023 8:45 Fluoride	0.
1/11/2023 8:45 Fluoride	•
7/11/2023 8:37 Fluoride	
7/11/2023 8:37 Fluoride	0.
15/11/2023 13:51 Fluoride	0.
	-
21/11/2023 9:24 Fluoride	<u> </u>
29/11/2023 8:23 Fluoride	0.
5/12/2023 9:40 Fluoride	0.
13/12/2023 9:57 Fluoride	
19/12/2023 11:42 Fluoride	0.
27/12/2023 15:31 Fluoride	0.
8/01/2023 8:40 Fluoride	0.
14/01/2023 10:54 Fluoride	
22/01/2023 9:30 Fluoride	<u> </u>
26/01/2023 10:04 Fluoride	-
30/01/2023 10:32 Fluoride	-
11/02/2023 9:40 Fluoride	-
19/02/2023 11:50 Fluoride	0.
21/02/2023 10:33 Fluoride	-
5/03/2023 10:01 Fluoride	-
7/03/2023 10:16 Fluoride	e 0.69 mg/l

Ngauranga Res Outlet Wainuiomata Gate House

19/03/2023 10:00 Fluoride	0.72 mg/l
23/03/2023 12:13 Fluoride	0.79 mg/l
29/03/2023 9:30 Fluoride	0.79 mg/l
6/04/2023 8:53 Fluoride	0.75 mg/l
12/04/2023 14:21 Fluoride	0.75 mg/l
20/04/2023 9:36 Fluoride	0.78 mg/l
29/04/2023 9:53 Fluoride	0.77 mg/l
6/05/2023 10:37 Fluoride	0.77 mg/l
14/05/2023 10:12 Fluoride	0.79 mg/l
20/05/2023 10:24 Fluoride	0.78 mg/l
28/05/2023 11:41 Fluoride	0.83 mg/l
31/05/2023 12:12 Fluoride	0.82 mg/l
11/06/2023 10:12 Fluoride	0.83 mg/l
17/06/2023 9:56 Fluoride	0.79 mg/l
19/06/2023 8:44 Fluoride	0.8 mg/l
28/06/2023 11:59 Fluoride	0.85 mg/l
16/07/2023 9:39 Fluoride	0.79 mg/l
21/07/2023 12:25 Fluoride	0.81 mg/l
25/07/2023 10:46 Fluoride	0.78 mg/l
2/08/2023 8:54 Fluoride	0.75 mg/l
10/08/2023 13:07 Fluoride	0.78 mg/l
22/08/2023 10:07 Fluoride	0.76 mg/l
28/08/2023 9:02 Fluoride	0.77 mg/l
9/09/2023 8:27 Fluoride	0.78 mg/l
13/09/2023 9:39 Fluoride	0.8 mg/l
23/09/2023 9:51 Fluoride	0.8 mg/l
23/09/2023 9:51 Fluoride	0.8 mg/l
29/09/2023 10:44 Fluoride	0.83 mg/l
29/09/2023 10:44 Fluoride	0.83 mg/l
3/10/2023 10:14 Fluoride	0.8 mg/l
3/10/2023 10:14 Fluoride	0.8 mg/l
11/10/2023 13:24 Fluoride	0.66 mg/l
11/10/2023 13:24 Fluoride	0.66 mg/l
17/10/2023 9:09 Fluoride	0.29 mg/l
17/10/2023 9:09 Fluoride	0.29 mg/l
25/10/2023 8:45 Fluoride	0.86 mg/l
25/10/2023 8:45 Fluoride	0.86 mg/l
31/10/2023 9:11 Fluoride	0.85 mg/l
31/10/2023 9:11 Fluoride	0.85 mg/l
8/11/2023 11:42 Fluoride	0.84 mg/l
8/11/2023 11:42 Fluoride	0.84 mg/l
14/11/2023 8:48 Fluoride	0.81 mg/l
14/11/2023 8:48 Fluoride	0.81 mg/l
22/11/2023 9:14 Fluoride	0.7 mg/l
30/11/2023 8:29 Fluoride	0.71 mg/l
8/12/2023 11:06 Fluoride	0.72 mg/l
14/12/2023 11:39 Fluoride	0.76 mg/l
20/12/2023 10:07 Fluoride	0.79 mg/l
28/12/2023 8:15 Fluoride	0.73 mg/l
3/01/2023 11:10 Fluoride	0.74 mg/l

Wainuiomata Gate House Waterloo WTP Treated Water Waterloo WTP Treated Water

4/01/2023 11:35 Fluoride	0.75 mg/l
7/01/2023 8:26 Fluoride	0.72 mg/l
9/01/2023 9:26 Fluoride	0.69 mg/l
11/01/2023 11:52 Fluoride	0.21 mg/l
13/01/2023 14:16 Fluoride	0.73 mg/l
16/01/2023 14:13 Fluoride	0.72 mg/l
17/01/2023 13:18 Fluoride	0.82 mg/l
20/01/2023 11:45 Fluoride	0.65 mg/l
24/01/2023 9:49 Fluoride	0.69 mg/l
25/01/2023 11:55 Fluoride	0.62 mg/l
27/01/2023 12:48 Fluoride	0.89 mg/l
13/02/2023 11:14 Fluoride	0.75 mg/l
15/02/2023 12:46 Fluoride	0.78 mg/l
17/02/2023 9:45 Fluoride	0.73 mg/l
20/02/2023 8:18 Fluoride	0.76 mg/l
22/02/2023 8:31 Fluoride	0.79 mg/l
24/02/2023 14:22 Fluoride	0.76 mg/l
27/02/2023 16:04 Fluoride	0.55 mg/l
28/02/2023 10:15 Fluoride	0.58 mg/l
3/03/2023 12:32 Fluoride	0.63 mg/l
6/03/2023 16:43 Fluoride	0.61 mg/l
8/03/2023 8:48 Fluoride	0.64 mg/l
10/03/2023 12:17 Fluoride	0.62 mg/l
13/03/2023 12:15 Fluoride	0.63 mg/l
15/03/2023 10:35 Fluoride	0.66 mg/l
17/03/2023 12:58 Fluoride	0.7 mg/l
20/03/2023 12:38 Fluoride	0.68 mg/l
22/03/2023 8:53 Fluoride	0.7 mg/l
24/03/2023 11:04 Fluoride	0.66 mg/l
27/03/2023 15:31 Fluoride	0.72 mg/l
28/03/2023 13:59 Fluoride	0.72 mg/l
31/03/2023 13:05 Fluoride	0.71 mg/l
3/01/2023 11:45 Fluoride	0.09 mg/l
4/01/2023 12:19 Fluoride	0.09 mg/l
6/01/2023 14:13 Fluoride	0.1 mg/l
9/01/2023 9:45 Fluoride	0.09 mg/l
11/01/2023 11:23 Fluoride	0.67 mg/l
13/01/2023 12:28 Fluoride	0.71 mg/l
16/01/2023 14:13 Fluoride	0.71 mg/l
17/01/2023 14:45 Fluoride	0.09 mg/l
20/01/2023 13:47 Fluoride	0.61 mg/l
24/01/2023 10:50 Fluoride	0.62 mg/l
25/01/2023 10:01 Fluoride	0.62 mg/l
27/01/2023 13:22 Fluoride	0.74 mg/l
13/02/2023 9:43 Fluoride	0.74 mg/l
15/02/2023 12:45 Fluoride	0.74 mg/l
17/02/2023 14:30 Fluoride	0.09 mg/l
20/02/2023 13:22 Fluoride	0.72 mg/l
22/02/2023 11:28 Fluoride	0.72 mg/l
24/02/2023 14:58 Fluoride	0.68 mg/l
27, 02, 2023 17.30 Huonae	0.00 mg/1

Waterloo WTP Treated Water Waterloo WTP Treated Water

27/02/2023 13:12 Fluoride	0.69 mg/l
28/02/2023 11:19 Fluoride	0.76 mg/l
3/03/2023 12:13 Fluoride	0.66 mg/l
6/03/2023 15:43 Fluoride	0.76 mg/l
8/03/2023 12:18 Fluoride	0.75 mg/l
10/03/2023 12:18 Fluoride	0.71 mg/l
13/03/2023 11:56 Fluoride	0.74 mg/l
15/03/2023 11:24 Fluoride	0.08 mg/l
17/03/2023 12:29 Fluoride	0.82 mg/l
20/03/2023 12:14 Fluoride	0.07 mg/l
22/03/2023 10:36 Fluoride	0.73 mg/l
24/03/2023 11:34 Fluoride	0.75 mg/l
27/03/2023 15:01 Fluoride	0.77 mg/l
28/03/2023 13:20 Fluoride	0.73 mg/l
31/03/2023 12:37 Fluoride	0.78 mg/l
14/04/2023 13:25 Fluoride	0.79 mg/l
17/04/2023 11:43 Fluoride	0.8 mg/l
19/04/2023 12:58 Fluoride	0.77 mg/l
21/04/2023 11:01 Fluoride	0.42 mg/l
24/04/2023 14:35 Fluoride	0.72 mg/l
26/04/2023 11:08 Fluoride	0.09 mg/l
26/04/2023 11:09 Fluoride	0.09 mg/l
28/04/2023 9:16 Fluoride	0.75 mg/l
1/05/2023 12:48 Fluoride	0.8 mg/l
3/05/2023 13:35 Fluoride	0.76 mg/l
5/05/2023 10:20 Fluoride	0.77 mg/l
8/05/2023 12:50 Fluoride	0.85 mg/l
10/05/2023 15:16 Fluoride	0.78 mg/l
12/05/2023 14:52 Fluoride	0.77 mg/l
15/05/2023 11:30 Fluoride	0.82 mg/l
17/05/2023 12:47 Fluoride	0.82 mg/l
19/05/2023 14:21 Fluoride	0.8 mg/l
22/05/2023 13:36 Fluoride	0.78 mg/l
24/05/2023 15:12 Fluoride	0.78 mg/l
26/05/2023 12:03 Fluoride	0.78 mg/l
29/05/2023 13:34 Fluoride	0.81 mg/l
31/05/2023 14:57 Fluoride	0.81 mg/l