

ovember 2018				
1. Product And Company Details				
Product name	Liquefied Petroleum Gas (LPG)			
Other names	LPG, LP Gas, Propane, Butane, Rockgas			
Use	Automotive, residential and commerci	ial fuel		
Company	Rockgas Limited, c/o Gas Service NZ Plymouth 4312	, 42 Connett Rd West, Bell Block, New		
Telephone	0800 762 542			
Emergency telephone	Fire Service: 111			
	Rockgas: 0800 427 345			
Fax	03 373 6443			
2. Hazards Identification	tion			
UN Number	Liquefied Petroleum Gas (LPG):	1075		
	Propane:	1978		
	Butane:	1011		
Hazchem Code	2YE			
Dangerous Goods (HSNO) Class	2.1.1A			
GHS Classification	Category: Flammable Gas Category 1			
	Signal Word: Danger			
	Hazard Statement: Extremely flammable gas			
3. Composition/Infor	mation on Ingredients			
Chemical Entity	CAS Number	Proportion		
LPG	68476-85-7	100% maximum		
Propane	74-98-6	100% maximum		
Butane	106-97-8	100% maximum		
Ethyl Mercaptan	75-08-1	0.0017% minimum (odourised LPG)		
4. First Aid Measures	6			
Swallowed	Due to high volatility of product, this is	s not likely to occur.		
Eyes	<ul> <li>Do not delay – flood eyes gently with clean tepid water (not hot) for at least 15 minutes, or flush eyes for as long as possible with sterile saline solution.</li> <li>Seek medical attention.</li> </ul>			
Skin	<ul> <li>Immediately bathe the area with large quantities of water (preferably tepid) for at least 15 minutes.</li> <li>If possible, remove any clothing splashed with liquid LPG that is not sticking to the skin.</li> <li>Place the injured person in a warm area and gradually rewarm the affected areas to normal body temperature.</li> <li>Do not apply any form of direct heat.</li> <li>Keep the person warm and comfortable.</li> <li>Loosen restrictive clothing.</li> <li>Gently cover the affected area with glad wrap or a wet, (not fibrous) material, ensuring that circulation is not restricted.</li> </ul>			

Rockgas Ltd November 2018 Version : 3.0 Page 1 of 5



November	2018	3
----------	------	---

ovember 2018			
Inhaled	<ul> <li>Do not give anything to eat or drink.</li> <li>Never leave the injured person unattended.</li> <li>Keep contaminated clothing away from ignition sources as some gas may be given off during thawing.</li> <li>Seek medical attention.</li> <li>Remove victim to fresh air.</li> </ul>		
	<ul> <li>If breathing has stopped, or irregular, apply artificial respiration.</li> <li>Seek medical attention.</li> </ul>		
Advice to doctor	Treat symptomatically.		
5. Fire Fighting Meas	sures		
Fire/Explosion hazard	<ul> <li>Evacuate area if required and remove ignition sources.</li> <li>Cut off gas supply if safe to do so – do not endanger life.</li> <li>Do not extinguish an LPG fire – allow gas to burn out.</li> <li>Drench and cool the LPG tank or cylinder with water spray from a safe distance.</li> <li>Wait for Emergency Services at a safe distance.</li> <li>Note: If ignition has occurred and water is not available or can't be sprayed on the tank or cylinder safely, the metal may weaken from the heat and explode. The potential affected area should be evacuated immediately, and emergency services notified from a safe location.</li> <li>Note: If it is essential to extinguish the fire then use only dry chemical powder extinguishers.</li> </ul>		
Combustion products  Advice to Firefighters	<ul> <li>Carbon dioxide, water vapour, traces of carbon monoxide and nitrogen oxides.</li> <li>Fumes, smoke, carbon monoxide and aldehydes can be formed during incomplete combustion.</li> <li>Note: Fire fighters may need self-contained breathing apparatus.</li> <li>Temperatures in a fire may cause the tank or cylinder(s) pressure relief</li> </ul>		
_	devices to open and release gas, or eventually rupture.  Cool the tank or cylinder(s) exposed to fire by applying water spray from a protected location.		
6. Accidental Releas	e Measures		
Personal precautions, protective equipment and emergency procedures	<ul> <li>Evacuate area if required and remove ignition sources.</li> <li>Stop flow of gas/liquid if safe to do so – do not endanger life.</li> <li>Move people from potential affected area, keep up-wind.</li> <li>Notify emergency services.</li> <li>Stop flow of gas/liquid if safe to do so.</li> <li>Spray water mist to disperse the gas cloud but avoid spraying water directly on leaking container as this may increase leakage.</li> <li>Prevent spillage from spreading or entering underground drains by blocking with wetted cloths, sand or earth.</li> </ul>		
7. Handling and Stor	age		
Safe handling	<ul> <li>Use of safe work practices are recommended to avoid eye or skin contact.</li> <li>Do not drag, drop or roll cylinders.</li> <li>The uncontrolled release of a gas under pressure may cause physical harm.</li> </ul>		
Conditions for safe storage	<ul> <li>Do not store near sources of ignition or incompatible materials.</li> <li>Cylinders should be stored upright, on a firm and stable surface.</li> <li>Cylinders should be stored in an accessible, well-ventilated area.</li> </ul>		

Rockgas Ltd November 2018 Version : 3.0 Page 2 of 5



November 2018

Additional details	<ul> <li>Health and Safety at Work (Hazardous Substances) Regulations 2017</li> <li>Hazardous Substances and New Organisms Act (HSNO) 1996</li> <li>NZS 5433 Transport of Dangerous Goods on Land 2012</li> <li>Relevant LPGA Codes of Practice</li> <li>AS/NZS 1596 Storage and Handling of LP Gas 2014</li> </ul>
	AS/NZS 1596 Storage and Handling of LP Gas 2014

#### 8. Exposure Controls/Personal Protection

Workplace exposure standard (WorkSafe January 2018):

- Propane is a simple asphyxiant and displaces oxygen from air. It presents an explosion hazard.
- Butane TWA 800 ppm, 1900 mg/m³
- LPG 1,000 ppm, 1800 mg/m<sup>3</sup>

#### 9. Engineering controls

Ignition sources	<ul> <li>Provide suitable ventilation to minimise an explosive atmosphere environment.</li> <li>Do not bring sources of ignition into a potential hazardous area atmosphere.</li> <li>Use only intrinsically safe electrical equipment. Do not bring items such as mobile phones, radios, cameras and other non-intrinsically safe electrical equipment into a potential hazardous area atmosphere</li> <li>Only use appropriate intrinsically safe (certified) tools and equipment in a potential hazardous area atmosphere</li> <li>Note: Hazardous area atmosphere zones are not always easy to define or measure, these zone extents may need to be clarified by a competent person.</li> </ul>	
Ventilation	Maintain adequate ventilation.  Note: LPG appliances can be hazardous when used in a poorly ventilated room.	
Usage	<ul> <li>Cylinders other than in-use forklift or automotive cylinders, must be used in the upright position.</li> <li>Use only equipment approved for LPG installations and installed in accordance with HSNO, Health and Safety at Work (Hazardous Substances) Regulations 2017, relevant LPGA Codes of Practice and, if applicable, AS/NZS 1596:2014 and/or the Gas Act 1992 (as amended).</li> </ul>	

#### 10. Personal protection

To protect against accidental release of pressurised LPG when there is a possibility of LPG liquid release (eg transferring):

#### Eyes/face

Wear full wrap-around safety glasses or goggles.

#### Hands

Wear appropriate thermal insulating gloves.

#### **Body**

Wear reduced static full body cover, cotton or other material with equivalent static and flame resistant properties.

#### Respiratory

Where an inhalation risk exists, wear self-contained breathing apparatus.

Appearance	Colourless gas, liquid under pressure. Typically has an unpleasant odour due to the addition of methyl mercaptan.				
	Propane Butane LPG (typical)				
Boiling Point (at atmospheric pressure)		-42°C	0°C	n/a	

Rockgas Ltd November 2018 Version: 3.0 Page 3 of 5



November 2018

Vapour Pressure	-10°C	256 kPa	-4 kPa	185 kPa
	0°C	388 kPa	40 kPa	292 kPa
	10°C	552 kPa	95 kPa	424kPa
	20°C	757kPa	172 kPa	593 kPa
	30°C	1004 kPa	266 kPa	796 kPa
Solubility in Water		75 mg/l	88 mg/l	
Specific Gravity Liquid (Water = 1)		0.508	0.573	0.537
Specific Gravity Gas (Air = 1)		1.58	2.06	1.73
Flash Point		-105°C	-60°C	-81°C
Flammability Limits		2.2 – 9.5%	1.5 – 9.0%	2 – 10%
Auto Ignition Temperature		468°C	430°C	450°C
1				

#### 11. Stability and Reactivity

- Stable under normal ambient conditions of storage and use.
- Avoid heat sources.

Can react violently with oxidising agents - Chlorine, pool chlorine or acids (e.g. nitric acid), heat and ignition sources.

### 12. Toxicological Information

Health effects from acute exposure			
Swallowed	Due to high volatility of product, this is not likely to occur.		
Eyes	Vaporising liquid will cause severe damage. Vapour will cause irritation.		
Skin	Vaporising liquid or liquid contact can result in cold burns.		
Inhaled	<ul> <li>May cause light-headedness, dizziness and drowsiness.</li> <li>Excessive exposure may cause unconsciousness or even death, due to asphyxiation (refers to vapour not liquid).</li> </ul>		
13. Health effects from chronic exposure			

No chronic systemic effects reported from industrial exposures.

Carcinogenicity	No known effect.
Mutagenicity	No known effect.
Teratogenicity	No known effect.

#### 14. Ecological Information

The Looking to the control of the co		
Ecotoxicity (aquatic and terrestrial)	LPG will vaporise rapidly when released to atmosphere. There are no known adverse ecological effects.	
Persistence and degradability	LPG will vaporise rapidly when released to atmosphere. There are no known adverse ecological effects.	
Potential to bioaccumulate	LPG will vaporise rapidly when released to atmosphere. There are no known adverse ecological effects.	
Mobility in soil	LPG will vaporise rapidly when released to atmosphere. There are no known adverse ecological effects.	

Rockgas Ltd November 2018 Version: 3.0 Page 4 of 5



Other adverse effects	LPG will vaporise rapidly when released to atmosphere. There are no known adverse ecological effects.				
15. Disposal Consider	ations		,	<u>,                                    </u>	
Get hold of Rockgas if disp	osal of LPG	is required	l.		
<ul> <li>required.</li> <li>Empty containers retain since residue is difficult</li> <li>Do NOT pressurise, cu sparks and other source</li> </ul>	n residue (liqu t to remove. t, weld, braze es of ignition. ust be carried	uid and/or e, solder, d They may	vapour) and can be rill, grind or expose y explode and caus	and the cylinder when no longer dangerous. Do not attempt to clean such containers to heat, flame, e injury or death.	
16. Transport Informat	tion				
Transport	Transport of	f LPG is co	ontrolled in accorda	nce with NZS 5433:2012	
Shipping name	Propane		Butane	Liquefied Petroleum Gas (LPG)	
UN Number	1978		1011	1075	
UN DG Class	2.1		2.1	2.1	
Subsidiary Risk(s)	None alloca	ted	None allocated	None allocated	
Hazchem code	2YE		2YE	2YE	
17. Regulatory Informa	17. Regulatory Information				
	Propane		Butane	LPG	
EPA Approval Numbers	HSR001010 HSR000989 HSR001009		HSR001009		
HSNO Group Standard	LPG Liquefied Petroleum Gas				
Poisons schedule number	None allocated				
LPG is a prescribed Hazardous Substance and its storage and handling is covered by various pieces of legislation.					
18. Other Information					
Acronyms	CAS – Chemical Abstract Service				
	EPA – Environmental Protection Authority				
	GHS – Globally Harmonized System				
	HSNO – Hazardous Substances and New Organisms				
	TWA – Time-weighted average				
Standards	AS/NZ 1596 – The Storage and Handling of LPG				
	NZ 5433 – Transport of Dangerous Goods on Land				
	i C				

Rockgas Ltd November 2018 Version: 3.0 Page 5 of 5

NZS 5435 - Specification for Liquefied Petroleum Gas (LPG)